

\$100 ANNUAL OPERATIONAL PERMIT FEE

**McKinney Fire Department
Fire Marshal's Office**

**Dispensing Flammable/Combustible Liquids
at Construction Sites
Operational Permit Application**

A permit is required in accordance with Section 105.6 of the 2015 International Fire Code for the operation of a motor fuel-dispensing facility or a repair garage.

Date of Application: _____

Project Name and Location

Name _____

Address: _____

Street Address _____

City _____ State _____ Zip _____

General Contractor/Project Superintendent

Emergency Contact: _____

Email Address: _____

Business Phone Number: _____ Mobile/Cell: _____

PERMITTING REQUIREMENTS.

1. Provide a Site Plan with this application to indicate the location(s) of all fuel tanks.
2. Indicate the size of the fuel tank(s).
3. Indicate secondary containment features.

LIST OF THE OPERATIONAL REQUIREMENTS CAN BE FOUND ON THE BACK.

I, *(Print Name)* _____ have read and understand the permit conditions for approval of this permit. I also understand that any variances to the conditions without the approval from the Fire Marshal's Office may result in a failed inspection, and additional fees and/or citations assessed in accordance with the City of McKinney Codes and Ordinances.

Signature _____ Date _____

OFFICIAL USE ONLY

\$100 Permit Fee Paid: \$ _____

Received By: _____

FUEL DISPENSING REQUIREMENTS

1. The tank's specific function is that of supplying fuel to motor vehicle fuel tanks only.
2. The dispensing hose does not exceed 100 feet (30 480 mm) in length.
3. The dispensing nozzle is of an approved type.
4. Location: Dispensing from tank vehicles shall be conducted at least 50 feet (15 240 mm) from structures, existing or planned, or combustible storage. Class II storage tanks and equipment shall be located a minimum of 25 feet from the nearest property line of property that can be built upon, and a minimum of 5 feet from the nearest street, alley or public way.
5. Signs prohibiting smoking or open flames within 25 feet (7620 mm) of the tank, vehicle, or the point of refueling are prominently posted on the tank.
6. Electrical devices and wiring in areas where fuel dispensing is conducted are in accordance with the 2016 NEC.
7. Tank dispensing equipment is operated only by designated personnel who are trained to handle and dispense motor fuels.
8. Provisions are made for controlling and mitigating unauthorized discharges.
9. The storage area shall be kept free from weeds, debris and combustible materials not necessary for the storage. The area surrounding the tank shall be kept clear of such material for a minimum of 15 feet.
10. Portable fire extinguishers shall meet the following requirements: At least one portable fire extinguisher having a capability of not less than 40:B shall be located within 30 ft. of any Class I or Class II liquid storage area.

Above list is not all-inclusive and is provided for information and guidance only.