

\$100 ANNUAL OPERATIONAL PERMIT FEE

**McKinney Fire Department
Fire Marshal's Office**

**Propane Exchange
Operational Permit Application**

An annual permit is required in accordance with Section 105.6 of the 2015 International Fire Code for the operation of a Liquefied Propane Gas (LPG) consumer exchange program.

Date of Application: _____

Business Name and Location

Name _____

Address: _____

Street Address _____

City _____ State _____ Zip _____

Emergency Contact: _____

Email Address: _____

Business Phone Number: _____ Mobile/Cell: _____

PERMITTING REQUIREMENTS

1. Provide a Site Plan with this application to indicate the location(s) of all exchange cages.
2. Indicate the total number of tanks and size of the tanks.

LIST OF THE OPERATIONAL REQUIREMENTS CAN BE FOUND ON THE BACK.

Any change, modification, or addition from the conditions of this permit must be reviewed for modifications and impact upon the permit conditions.

This permit must be clearly posted in conspicuous place, or as mandated by a Fire Code Official, and available upon request.

Failure to comply with the provisions of this permit, or when a violation is found by inspection, will result in revocation of this permit and/or issuance of a citation.

I, (*Print Name*) _____ have read and understand the permit conditions for approval of this permit. I also understand that any variances to the conditions without the approval from the Fire Marshal's Office may result in a failed inspection, and additional fees and/or citations assessed in accordance with the City of McKinney Codes and Ordinances.

Signature _____ Date _____

OFFICIAL USE ONLY

\$100 Permit Fee Paid: \$ _____

Received By: _____

LIQUEFIED PROPANE GAS (LPG) CONSUMER EXCHANGE

1. Cages shall be located at least 20 feet from openings into buildings, fuel dispensing devices, or any portion of a building used as a means of egress.
2. Cages shall be located at least 10 feet from the public way and fire lanes.
3. Cages shall be located a minimum of 3 ft. from any exterior wall.
4. No Smoking signs shall be posted at the cages and within 25 ft.
5. NFPA 704 diamond shall be posted on each cage.
6. Bollard protection in accordance with Section 312.
 - a. 4 inch steel pipes filled with concrete.
 - b. Spaced no more than 4 ft. apart.
7. Cages shall be kept free of combustible materials for a distance of 10 ft. on all sides.
8. Cages shall be lockable and tamper proof.
9. Signs indicating exchange procedures, company name and 24 hour contact shall be posted.

Above list is not all-inclusive and is provided for information and guidance only.