

WAYFARING SIGN DETAIL





IFC SECTION 505.3

A wayfaring sign shall be provided for all new and existing multi building developments in which multiple buildings are addressed off a single address, such as in an apartment complex, or when the nature and arrangement of the buildings, such signage would be conducive to navigation. Such signs shall be placed at all points of entry into the development, or as required by the Fire Code Official.

Minimum Requirements

1. Provide a simplified Site Plan layout of the development. *(example provided below)*
2. Indicate all vehicle entry and exit points.
3. Minimum 36 inch by 36 inch.
4. Shall be lighted or all reflective.
5. Indicate major buildings and building numbers.
6. Indicate the name, address and phone number.



 MCKINNEY FIRE DEPARTMENT FIRE MARSHAL'S OFFICE	SIZE	FSCM NO	DWG NO	REV
	8.5X11		WAYFARING.SIGN.1	1
DRAWN	ANDREW BARR, CFPS	SCALE	SHEET	1 OF 1
ISSUED	SEPTEMBER 2018	1 : 1		