

\$100 ANNUAL OPERATIONAL PERMIT FEE

**McKinney Fire Department
Fire Marshal's Office**

**Flammable Combustible Finishes
Operational Permit Application**

A permit is required in accordance with Section 105.6 of the 2015 International Fire Code for the operation of a flammable/combustible finishes in accordance with Chapter 24.

Date of Application: _____

Business Name and Location

Name _____

Address: _____
Street Address

_____ **City** _____ **State** _____ **Zip**

Emergency Contact: _____

Email Address: _____

Business Phone Number: _____ **Mobile/Cell:** _____

PERMITTING REQUIREMENTS

1. Provide a Site Plan and Floor Plan with this application to indicate the location(s) of all flammable and/or combustible spray finishing and dipping operations. This can include, but not limited to; spray-on bed liners, powder coating, painting, electrostatic beds, dipping tanks, and spray foam.
2. Location of all stored and in-use flammable and/or combustible liquids.

LIST OF THE OPERATIONAL REQUIREMENTS CAN BE FOUND ON THE BACK.

Any change, modification, or addition from the conditions of this permit must be reviewed for modifications and impact upon the permit conditions.

This permit must be clearly posted in conspicuous place, or as mandated by a Fire Code Official, and available upon request.

Failure to comply with the provisions of this permit, or when a violation is found by inspection, will result in revocation of this permit and/or issuance of a citation.

I, *(Print Name)* _____ have read and understand the permit conditions for approval of this permit. I also understand that any variances to the conditions without the approval from the Fire Marshal's Office may result in a failed inspection, and additional fees and/or citations assessed in accordance with the City of McKinney Codes and Ordinances.

Signature _____ Date _____

OFFICIAL USE ONLY

\$100 Permit Fee Paid: \$ _____

Received By: _____

FLAMMABLE/COMBUSTIBLE FINISHES

1. Flammable and combustible liquids shall be stored within approved cabinets or storage tanks.
2. Protection against sources of ignition shall be provided in accordance with Sections 2403.2.1 and 2403.2.8
3. Ventilation shall be provided as required by the Mechanical Code.
4. Welding, cutting and similar spark-producing operations shall not be conducted in or adjacent to spray areas or dipping or coating operations unless precautions have been taken to provide safety.
5. Smoking shall be prohibited in spray spaces or vapor areas. "No Smoking" signs complying with Section 310 shall be conspicuously posted in such areas.
6. Equipment or apparatus that is capable of producing sparks or particles of hot metal that would fall into a spray space or vapor area shall be totally enclosed.
7. Open flames and spark-producing devices shall not be located in spray spaces or vapor areas and shall not be located within 20 feet of such areas unless separated by a permanent partition.
8. Electrical wiring and equipment located outside of, but within 5 feet horizontally and 3 feet vertically of openings in a spray booth or a spray room shall be approved for Class I, Division 2 or Class II, Division 2 hazardous locations, whichever is applicable.
9. Electrical wiring and equipment in spray spaces and vapor areas shall be of an explosion-proof type approved for use in such hazardous locations. Such areas shall be considered to be Class I, Division 1 or Class II, Division 1 hazardous locations in accordance with the ICC Electrical Code.
10. The storage, use and handling of flammable and combustible liquids shall be in accordance with this section and Chapter 57.

Above list is not all-inclusive and is provided for information and guidance only.